

FIRE SAFETY CERTIFICATE

No. 20/2023


Dated: 09.10.2023

Certified that the **M.A.M EXEL PUBLIC SCHOOL**, P.K.Pudur, Guruvareddiyur – 638504, Anthiyur Taluk, Erode district comprised of Block I - Ground floor, First Floor & Second Floor, Block II – Ground Floor, First Floor Block III – Ground Floor, First Floor & Second Floor owned/occupied by **M.A.M EXEL PUBLIC SCHOOL**, P.K.Pudur, Guruvareddiyur - 638504, Anthiyur Taluk, Erode district (Name of the institution) have complied with the Fire prevention and fire safety requirements in accordance with Rule of State / UT Fire service Rules, and verified by the officers concerned of fire Service on **07.10.2023** (date of inspection) in the presence of Nirmala Devi, Principal, M.A.M EXEL PUBLIC SCHOOL, P.K.Pudur, Guruvareddiur, Anthiyur Taluk, Erode district - 638504, (name and addresses of the Manager/secretary or his Representative) and that the building/ premises is fit for occupancy up to classes **Xth Standard (X/XII)** with effect from **09.10.2023 to 08.10.2024** for a period of 1 Years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.This it should be insured that the available fire safety equipment is always in good working condition.
- 2.Electric wiring in the entire building shall be checked and certified by the competent authority.
- 3.As per Hon'ble Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency and the school shall observe the fire safety day on April 14th of every year by conducting fire safety drills with coordinate with fire service department.

Issued on 09.10.2023 (date of issue) at Anthiyur by

* Strick out Whichever is not applicable.


STATION OFFICER,
FIRE AND RESQUE SERVICE
ANTHIYUR-638 501,
Signature with Seal :
Name : P. ROBERT
Designation : SPECIAL STATION OFFICER.

Name & Address of Department/office : FIRE AND RESQUE STATION, ANTHIYUR.

To:

The Correspondent,

M.A.MEXEL Public School,

P.K. Pudur, Guruvareddiyur 638504, Erode District. Tamilnadu